



SE Tennis and Learning Center Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005648	5/16/2020	5/16/2021	1	Cooler	In hallway adjacent to girls' restroom	WF-05162020-005648	4/1/2021	FT-FY21-032021-005648-A	<1	FT-FY21-032021-005648-B	<1
WS- 005651	5/16/2020	5/16/2021	1	Cooler	In hallway adjacent to staff restroom Low	WF-05162020-005651	4/1/2021	FT-FY21-032021-005651-A	<1	FT-FY21-032021-005651-B	<1
WS- 005652	5/16/2020	5/16/2021	1	Cooler	In hallway adjacent to staff restroom High	WF-05162020-005652	4/1/2021	FT-FY21-032021-005652-A	<1	FT-FY21-032021-005652-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005650	2/9/2021	2/9/2022	1	Food Prep Sink	In kitchen	WF-02092021-005650	4/1/2021	FT-FY21-032021-005650-A	<1	FT-FY21-032021-005650-B	<1